

TABLE 10-A—MINIMUM EGRESS REQUIREMENTS¹

| USE ² | MINIMUM OF TWO MEANS OF EGRESS ARE REQUIRED WHERE NUMBER OF OCCUPANTS IS AT LEAST | OCCUPANT LOAD FACTOR ³ (square feet) |
|--|---|--|
| | | × 0.0929 for m ² |
| 1. Aircraft hangars (no repair) | 10 | 500 |
| 2. Auction rooms | 30 | 7 |
| 3. Assembly areas, concentrated use (without fixed seats) Auditoriums Churches and chapels Dance floors Lobby accessory to assembly occupancy Lodge rooms Reviewing stands Stadiums Waiting area | 50 | 7 |
| 4. Assembly areas, less-concentrated use Conference rooms Dining rooms Drinking establishments Exhibit rooms Gymnasiums Lounges Stages Gaming: keno, slot machine and live games area | 50 | 15 |
| 5. Bowling alley (assume no occupant load for bowling lanes) | 50 | 4 |
| 6. Children's homes and homes for the aged | 6 [for SFM] 7 | 80 |
| 7. Classrooms | 50 | 20 |
| 8. Congregate residences | 10 | 200 |
| 9. Courtrooms | 50 | 40 |
| 10. Dormitories | 10 | 50 |
| 11. Dwellings | 10 | 300 |
| 12. Exercising rooms | 50 | 50 |
| 13. Garage, parking | 30 | 200 |
| 14. Health care facilities— Sleeping rooms Treatment rooms | 8 [for SFM] 7 10 [for SFM] 7 | 120 240 |
| 15. Hotels and apartments | 10 | 200 |
| 16. Kitchen—commercial | 30 | 200 |
| 17. Library— Reading rooms Stack areas | 50 30 | 50 100 |
| 18. Locker rooms | 30 | 50 |
| 19. Malls (see Chapter 4) | — | — |
| 20. Manufacturing areas | 30 | 200 |
| 21. Mechanical equipment room | 30 | 300 |
| 22. Nurseries for children (day care) | 7 | 35 |
| 23. Offices | 30 | 100 |
| 24. School shops and vocational rooms | 50 | 50 |
| 25. Skating rinks | 50 | 50 on the skating area; 15 on the deck |
| 26. Storage and stock rooms | 30 | 300 |
| 27. Stores—retail sales rooms Basements and ground floor Upper floors | 50 50 | 30 60 |
| 28. Swimming pools | 50 | 50 for the pool area; 15 on the deck |
| 29. Warehouses ⁵ | 30 | 500 |
| 30. All others | 50 | 100 |
| 31. Group R, Division 2 | 10 | 300 ⁶ |
| 32. Group R, Division 6 | 10 | — |

¹Access to, and egress from, buildings for persons with disabilities shall be provided as specified in Chapter 11.

²For additional provisions on number of exits from Groups H and I Occupancies and from rooms containing fuel-fired equipment or cellulose nitrate, see Sections 1007.4, 1007.5 and 1007.7, respectively.

³This table shall not be used to determine working space requirements per person.

⁴Occupant load based on five persons for each alley, including 15 feet (4572 mm) of runway.

⁵Occupant load for warehouses containing approved high rack storage systems designed for mechanical handling may be based on the floor area exclusive of the rack area rather than the gross floor area.

⁶The number of clients for occupancy classification shall be determined by the licensing authority.

C
A
L

C
A
L
I
I

C
A
C
A

C
A